



AVK Series 27 Dry Barrel Hydrants

AWWA/UL/FM Certificate of Compliance

This letter is to certify that the Series 27 Dry Barrel Fire Hydrants manufactured by American AVK Company in Minden, Nevada, meet or exceed the standards established by the AWWA (C502 and C550), UL 246 and FM1510. The hydrants are listed with UL, ULC and are FM approved.

Each hydrant is tested, after assembly, to a static pressure of 500 psi. The AWWA, UL and FM working pressure is rated to 250 psi.

In addition, all American AVK fire hydrants have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information, please feel free to contact us.

On behalf of American AVK,

A handwritten signature in black ink that reads "John Wilber".

John Wilber

VP Engineering
American AVK Company

American AVK Company

2155 Meridian Blvd
Minden, NV 89423

Tel: (775) 552-1400
Fax: (775) 552-1031

sales@avkus.com
www.americanavk.com

Expect... The logo for American AVK Company, featuring the letters 'AVR' in a bold, blue, stylized font.