



AVK Series 45 and Series 55 Gate Valves

AWWA C515 Certificate of Compliance

This letter is to certify that all Series 45 and Series 55 resilient wedge ductile iron gate valves manufactured by American AVK Company in Minden, Nevada, meet or exceed the standards established by AWWA for Resilient Seated Gate Valves; ANSI/AWWA C515.

The valves are rated by American AVK Co. for a working pressure of 250 psi. Each valve is shell tested to 500 psi and tested for complete operation at 250 psi and 25 psi before shipment.

In addition, all American AVK gate valves have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information, please feel free to contact us.

On behalf of American AVK,

A handwritten signature in black ink, appearing to read "John Wilber", is positioned above the printed name.

John Wilber

VP Engineering
American AVK Company

American AVK Company

2155 Meridian Blvd
Minden, NV 89423

Tel: (775) 552-1400
Fax: (775) 552-1031

sales@avkus.com
www.americanavk.com

Expect... The logo for American Valve Research (AVR) is displayed in a bold, blue, stylized font. The letters 'A', 'V', and 'R' are interconnected, with the 'V' and 'R' having a distinctive shape that suggests a valve or a mechanical component.